

The following items are clarifications and modifications to the Bid Documents dated February 1, 2020. All listed items shall become part of the Bid Documents.

**The following are answers to questions from bidders:**

**Architectural:**

We have a few more questions on Elm Street:

1. Specs call for new soffit venting - Building has existing soffit vents - are we replacing them?
  - *Existing soffits vents are to remain. We're including in spec in the event that they are needed to be replaced.*
2. Siding Alternate - Add siding to the first floor on the Elms Street and Fore Street sides of the building .... How far down Fore Street, just the building? or include the garage?
  - *The garage is not in this scope of work. See below for extent of new siding of the main building:*



New Siding  
Ends Here

New Siding



3. Where is Door #37?

New Siding

- *Door #37 is an existing door that is being demolished. Please omit from drawing set.*

END OF ADDENDUM